



**Reinforcement Notes:**

SIDES & BOTTOM: 6x6 10/10 W.W.F.  
4000 PSI CONCRETE

TOP: 6x6, 10/10 W.W.F. AND  
3/8" RODS 9" O.C. EACH WAY  
4000 PSI CONCRETE

NOTES: START REINFORCING RODS 6"  
FROM OUTSIDE EDGE OF TOP  
EXTEND REINFORCING RODS TO WITHIN  
1/2" OF EDGE OF TOP

ALL DIMENSIONS IN INCHES

**ECOLOGICAL TANKS, INC**

2247 HWY 151 NORTH  
DOWNSVILLE, LA 71234  
318-644-0397 OFFICE  
318-644-7257 FAX

**Model: ASO500C 5 + 6**

PATENT PENDING

Treatment Capacity: 500 GPD

Flow Line Volume: 762 GAL.

B.O.D. Loading: 1.25#/day

NO PART OF THIS DOCUMENT MAY BE REPRODUCED,  
STORED IN ANY RETRIEVAL SYSTEM, OR TRANSMITTED  
IN ANY FORM OR BY ANY MEANS, ELECTRONIC,  
MECHANICAL, PHOTOCOPYING, RECORDING OR  
OTHERWISE WITHOUT THE PRIOR WRITTEN PERMISSION  
OF ECOLOGICAL TANKS, INC.

SCALE:  
NTS

DATE  
3/22/19

DRAWING NO.  
ASO500C 5 + 6.pdf