



Reinforcement Notes:

SIDES & BOTTOM: 6x6 10/10 W.W.F.
4000 PSI CONCRETE

TOP: 6x6 10/10 W.W.F. AND
3/8" RODS 9" O.C. EACH WAY
4000 PSI CONCRETE

NOTES: START REINFORCING RODS 6"
FROM OUTSIDE EDGE OF TOP
EXTEND REINFORCING RODS TO WITHIN
1/2" OF EDGE OF TOP

SCALE: Not to Scale	Ecological Tanks, Inc. 2247 Hwy 151 North Downsville, LA 71234	
DRAWN BY: JKC		
DATE: November, 2008	3-Compartment Aerobic Treatment Unit	
MODEL: AS500L-C 4+75	REV. B	